



270, Sector-37, Udyog Vihar, Phase-6,  
Gurgaon - 122 001 (NCR) India  
Lab Tel.: 0124-4384380-1  
24x7 Customer Care : 9312430446  
9810098791  
Visit us at : www.qualityanalyst.net  
E-mail : support@qualityanalyst.net

Partner-Global Water Partnership  
ISO 9001:2015 Certified  
ISO 14001:2015 Certified  
CIN : U85195DL2003PTC121385  
24 Years of Analytical Expertise

**Certificate of Analysis**

Quality Standard	Parameters as desired	
Issued to	-	St. Marks Sr. Sec Public School, A Block, Meera Bagh, New Delhi-110087
Kind attn.	-	Manager
Analysis no.	-	25021203
Nature of Sample	-	Water Sample marked Drinking
Sample received on	-	12 <sup>th</sup> February 2025
Report Date	-	17 <sup>th</sup> February 2025
Analysis Dates	-	12 <sup>th</sup> February 2025 to 17 <sup>th</sup> February 2025
Sample Packing	-	Sterilized and Pet Bottles
Sample Receipt	-	Picked by Lab
Sampling Method	-	Grab Sampling

	PARAMETER	UNIT	RESULT	TEST METHOD	DESIRED LIMIT
General	Color	Hazen	05	IS 3025 Part 4	05
	Odor	Unit Less	Unobjectionable	IS 3025 Part 5	Unobjectionable
	Taste	Unit Less	Agreeable	IS 3025 Part 6	Agreeable
Bacteria	Coliform	CFU/100ml	Absent	IS1622	10
	E.Coli	CFU/100ml	Absent	IS1622	Absent
Physical	pH	Unit Less	7.53	IS 3025 Part 11	6.5-8.5
	Conductivity	microS at 25°C	331	IS 3025 Part 14	...
	Turbidity	NTU	1.0	IS 3025 Part 10	5
Chemical	Total Dissolved Solids	mg/l	172	IS 3025 Part 16	500
	M. Alkalinity as CaCO3	mg/l	108.5	IS 3025 Part 23	200
	Total Hardness as CaCO3	mg/l	129	IS 3025 Part 21	300
	Chlorides as Cl	mg/l	16.2	IS 3025 Part 32	250
	Total Iron as Fe	mg/l	0.01	IS 3025 Part 53	0.3
	Residual Free Chlorine	mg/l	Nil	IS 3025 Part 35	0.20

Remarks: The no. of parameters tested are 14 only. The results indicate that the Quality of Water may be considered to be within the desired limits for Drinking as per IS:10500, in regard to the parameters tested only. The report is issued subject to the terms & conditions as mentioned overleaf.

Chemist

*[Signature]*  
Mrs. RITIKA ANAND  
PRINCIPAL  
St. Mark's Sr. Sec. Public School  
A-Block, Meera Bagh,  
New Delhi-110087

Authorized Signatory



**QUALITY LAB** is a trademark and fully owned unit of Quality Analyst & Labs Pvt. Ltd.

Office : 382, Vardhman Charve Plaza-5, Plot No. 20, KP Block Commercial Centre, Pitam Pura, New Delhi-110088  
Exclusive representatives in South Asia for Green Seal, Inc., 1001, Connecticut Avenue, NW, Suite, 827, Washington, DC, USA  
Exclusive representatives in India for Sens Aqua, Naeringshagen No. 7340. OPPDAL, Norway  
Exclusive representatives in india for Femko Technical Control and Certification Ltd., Izmir, Turkey for CE Marking