




270, Sector-37, Udyog Vihar, Phase-6,  
Gurgaon - 122 001 (NCR) India  
Lab Tel.: 0124-4384380-1, Fax : 0124-4384382  
24x7 Customer Care : 9312430446  
9810098791  
Visit us at : www.qualityanalyst.net  
E-mail : sales@qualityanalyst.net

ISO 9001: 2015 Certified  
ISO 14001:2015 Certified  
CRISIL Rated  
NABL Accredited  
CIN : U85195DL2003PTC121385  
19 Years of Analytical Expertise

## Certificate of Analysis

Quality Standard		Parameters as desired				
Issued to	-	St. Marks Girls Senior Secondary School, A Block, Meera Bagh, New Delhi				
Kind attn.	-	Mr.				
Analysis no.	-	19061904				
Nature of Sample	-	Water Sample marked Drinking				
Sample received on	-	19th June 2019				
Report Date	-	24th June 2019				
Analysis Dates	-	19th June 2019 to 24th June 2019				
Sample Packing	-	Sterilized and Pet Bottles				
Sample Receipt	-	Picked by Lab				
Sampling Method	-	Grab Sampling				
	PARAMETER	UNIT	RESULT	TEST METHOD	DESIRED LIMIT	
General	Color	Hazen	05	IS 3025 Part 4	05	
	Odor	Unit Less	Unobjectionable	IS 3025 Part 5	Unobjectionable	
	Taste	Unit Less	Agreeable	IS 3025 Part 6	Agreeable	
Bacteria	Coliform	CFU/100ml	Absent	IS1622	10	
	E.Coli	CFU/100ml	Absent	IS1622	Absent	
Physical	pH	Unit Less	7.17	IS 3025 Part 11	6.5-8.5	
	Conductivity	microS at 25°C	188	IS 3025 Part 14	---	
	Turbidity	NTU	1.0	IS 3025 Part 10	5	
	Total Dissolved Solids	mg/l	109	IS 3025 Part 16	500	
Chemical	M. Alkalinity as CaCO <sub>3</sub>	mg/l	55.3	IS 3025 Part 23	200	
	Total Hardness as CaCO <sub>3</sub>	mg/l	80.3	IS 3025 Part 21	300	
	Chlorides as Cl	mg/l	13.7	IS 3025 Part 32	250	
	Total Iron as Fe	mg/l	0.01	IS 3025 Part 53	0.3	
	Residual Free Chlorine	mg/l	Nil	IS 3025 Part 35	0.20	
Remarks: The no. of parameters tested are 14 only. The results indicate that the Quality of Water may be considered to be within the desired limits for Drinking as per IS:10500, in regard to the parameters tested only. The report is issued subject to the terms & conditions as mentioned overleaf.						
Chemist		 <b>MS. SHEENA KALENGA</b> Principal St. Mark's Girls Sr. Sec. School Meera Bagh, New Delhi-110087			Authorized Signatory	



**QUALITY LAB** is a trademark and fully owned unit of Quality Analyst & Labs Pvt. Ltd.

Office : 382, Vardhman Charve Plaza-5, Plot No.20, KP Block Commercial Centre, Pitam Pura, New Delhi-110088

Exclusive representatives in South Asia for Green Seal, Inc., 1001, Connecticut Avenue, NW, Suite, 827, Washington, DC, USA

Exclusive representatives in India for Sens Aqua, Naeringshagen No. 7340. OPPDAL, Norway